

Certificate

No. z3666a-14-E

Customer:

Dätwyler Cables GmbH
Auf der Roos 4-12
65795 Hattersheim, Germany

Class EA

Test sample(s):

Connector:

RJ45 module KS-T Plus 1/8 tool-less Cat.6A (IEC) shielded

Part-no.: 418 061

Data Cable:

DATWYLER CU 7080 4P AWG23 S/FTP Cat.7 FRNC/LSZH

Part no.: 182 911 (simplex), 182 912 (duplex),
188 509 (simplex HighS), 191 899 (duplex HighS),
188 508 (simplex HighP)

Applied standard(s):

ISO/IEC 11801 Ed.2.2 (2011-06)

Result(s):

The sample meets the limits of the specified standards and regulations.

2 Connector Permanent Link, Copper, Class EA

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **P3666a-14-E** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of issue.

Bexbach, 11. August 2014



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG

In der Kolling 13
66450 Bexbach / Germany

P0 box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.